



# *1A54K6 Test Manual*


## *Alarm Panel – (16 Point)*

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



 User Guide

 Test Manual

# 1A54K6 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1A54.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1A54\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1A54_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1A54\\_application.pdf](http://www.rmspl.com.au/solutions/1A54_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1A54acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	20/03/2006	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



**1.0 HARDWARE SPECIFICATIONS – 1A054K06 [B][B][B]**

**1.1 Alarm Points**

[B] 16 Point

**1.2 Auxiliary Supply**

[B] 40 – 275 VAC, 40 – 300 VDC

**1.3 Custom Engraved Text**

[B] Required

**1.4 Non-Standard Features**

Hardware specifications not described in Technical Bulletin. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 150-054-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

**3.0 CONNECTION DIAGRAM**

