



1A54K12 Test Manual

Alarm Panel – (8 Point)

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide

Test Manual

1A54K12 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1A54.pdf>
- User Guide: http://www.rmspl.com.au/userguide/1A54_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/1A54_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/1A54acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

| Order Number | Serial Number |
|--------------|---------------|
| | |

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

| Issue | Date | Summary of changes |
|-------|------------|--------------------|
| A | 13/09/2007 | Released. |
| | | |
| | | |
| | | |

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

| Author | Checked & Registered | .pdf file created | Released |
|--------|----------------------|-------------------|----------|
| DG | DW | DW | |



1.0 HARDWARE SPECIFICATIONS – 1A054K12 [J][A][#][#]

- 1.1 Alarm Points** [J] 8 Points x 24 Outputs
- 1.2 Auxiliary Supply** [A] 20 – 70 VDC
- 1.3 Custom Engraved Text** [#] Specified at order
- 1.4 Status Inputs Firmware** [#] Specified at order
- 1.5 Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 150-054-800 and in accordance with the relevant International (IEC) Standards.

| PASSED BY | DATE |
|-----------|------|
| | |

3.0 CONNECTION DIAGRAM

