



# 1A54K13 Test Manual

## Alarm Panel – (8 Point)

relay monitoring systems pty ltd

### **Advanced Protection Devices**



User Guide

Test Manual

# 1A54K13 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1A54.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1A54\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1A54_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1A54\\_application.pdf](http://www.rmspl.com.au/solutions/1A54_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1A54acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	26/05/2008	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



**1.0 HARDWARE SPECIFICATIONS – 1A054K13 [J][B][#][#]**

- 1.1 Alarm Points** [J] 8 Points x 24 Outputs
- 1.2 Auxiliary Supply** [B] 40 – 275 VAC, 40 – 300 VDC
- 1.3 Custom Engraved Text** [#] Specified at order
- 1.4 Status Inputs Firmware** [#] Specified at order
- 1.5 Non-Standard Features**  
Hardware specifications not described in Technical Bulletin. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 150-054-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

**3.0 CONNECTION DIAGRAM**

