



Order Number

Serial Number

## PRODUCT/TEST MANUAL

**1L71K1**

**POWER SUPPLY & TRANSMIT RELAY**

<b>Issue Level</b>	<b>Date</b>	<b>Summary of changes</b>
A	9/07/01	Initial issue.

Due to RMS continuous product improvement policy this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

<b>Author</b>	<b>Checked &amp; Registered</b>	<b>.pdf file created</b>	<b>Released</b>
AF	MW	MW	



**7. GENERAL & FUNCTIONAL**

- a) Check that unit operates satisfactorily over the range of 216 to 264 volts auxiliary supply.
- b) Ensure contacts operate correctly
- c) Check that the relay is electrically sound and mechanically robust as per Standard Inspection & Test Schedule 903-000-026

PASS

TESTED BY : \_\_\_\_\_ DATE : \_\_\_\_\_

**8. CONNECTION DIAGRAM**

