



# 1S20K2 Test Manual


## Arc Fault Monitor

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



 User Guide

 Test Manual

# 1S20K2 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1S20.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1S20\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1S20_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1S20\\_application.pdf](http://www.rmspl.com.au/solutions/1S20_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1S20acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	18/07/2005	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DHW	DHW	



**1.0 HARDWARE SPECIFICATIONS – 1S020K02 [C][A][B]**

- 1.1 Auxiliary Supply** [C] 36 - 150VDC
- 1.2 Mounting Style** [A] Panel Mount
- 1.3 Available Sensor Inputs** [B] Up to 3
- 1.4 Non-Standard Features**  
Hardware specifications not described in Technical Bulletin. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification [198-020-800](#) and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

**3.0 CONNECTION DIAGRAM**

