




1X30K3 Test Manual

Trip Circuit Supervision Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



1X30K3 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/1X30.pdf>
- User Guide: http://www.rmspl.com.au/userguide/1X30_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/1X30_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/1X30acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	20/11/2006	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 1X030K03 [A][B][A]

1.1 Supervision Voltage

[A] 24VDC

1.2 Supervision Scheme

[B] Green LED. Normal = ON

1.3 Custom Front Panel Label

[A] Not required.

1.4 Non-Standard Features

Hardware specifications not described in Technical Bulletin.

None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 156-030-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

