



# *1X30K11 Test Manual*

## *Trip Circuit Supervision Relay*

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



User Guide



Test Manual



# 1X30K11 Test Manual

## Links to Other Documents

---

- Technical Bulletin: <http://www.rmspl.com.au/handbook/10.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/1x30\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/1x30_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/1x30\\_application.pdf](http://www.rmspl.com.au/solutions/1x30_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/1x30acad.htm>

## Test Certification

---

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

---

Issue	Date	Summary of changes
A	07/10/2009	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DG	



**1.0 HARDWARE SPECIFICATIONS – 1X030K11 [E][A][#]**

- 1.1 Supervision Voltage** [E] 125VDC
- 1.2 Supervision Scheme** [A] Red LED. Normal = OFF
- 1.3 Custom Front Panel Label** [#] Only if requested.
- 1.4 Non-Standard Features**  
Hardware specifications not described in Technical Bulletin. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 156-030-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

**3.0 CONNECTION DIAGRAM**

