



2C63K13 Test Manual

Definite Time Current Check Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



2C63K13 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2C63.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2C63_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/2C63_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/2C63acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	19/08/2005	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 2C063K13 [B][A][A][B][A][B][B]

- 1.1 Auxiliary Supply** [B] 40 - 275 VAC, 40 - 300 VDC
- 1.2 Current Setting** [A] 5 – 50%
- 1.3 CT Input Rating** [A] 1Amp Nom
- 1.4 Internal Timer Initiate Voltage** [B] 75 – 150VDC
- 1.5 Remote Flag Reset Voltage** [A] 24 - 80VDC
- 1.6 Configurable Output Contacts** [B] Instantaneous, Common Reset
- 1.7 Relay Initiate Logic Voltage** [B] 75 - 150VDC
- 1.8 Non-Standard Features**
Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 159-063-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

