



2C63K15 Test Manual

Definite Time Current Check Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



2C63K15 Test Manual

Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2C63.pdf>
- User Guide: http://www.rmspl.com.au/userguide/2C63_user_guide.pdf
- Application: http://www.rmspl.com.au/solutions/2C63_application.pdf
- Acad Case Drawings: <http://www.rmspl.com.au/2C63acad.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	25/05/2006	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



1.0 HARDWARE SPECIFICATIONS – 2C063K15 [B][A][B][B][B][A][H]

1.1 Auxiliary Supply	[B]	40 - 275 VAC, 40 - 300 VDC
1.2 Current Setting	[A]	5 – 50%
1.3 CT Input Rating	[B]	5Amp Nom
1.4 Internal Timer Initiate Voltage	[B]	75 – 150VDC
1.5 Remote Flag Reset Voltage	[B]	75 - 150VDC
1.6 Configurable Output Contacts	[A]	Delayed, Common Reset
1.7 Relay Initiate Logic Voltage	[H]	Not Fitted
1.8 Non-Standard Features Hardware specifications not described in Technical Bulletin.		None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 159-063-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

