



# *2P48K1 Test Manual*

## *Phase Failure Relay*

relay monitoring systems pty ltd

---

### **Advanced Protection Devices**



User Guide



Test Manual



# 2P48K1 Test Manual

## Links to Other Documents

- Technical Bulletin: <http://www.rmspl.com.au/handbook/2P48.pdf>
- User Guide: [http://www.rmspl.com.au/userguide/2P48\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/2P48_user_guide.pdf)
- Application: [http://www.rmspl.com.au/solutions/2948\\_application.pdf](http://www.rmspl.com.au/solutions/2948_application.pdf)
- Acad Case Drawings: <http://www.rmspl.com.au/2P48acad.htm>

## Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

Issue	Date	Summary of changes
A	09/08/2000	Released.
B	16/04/2004	New PCB design
C	12/07/2005	Document reformat

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
ERL	DG	DG	



**1.0 HARDWARE SPECIFICATIONS – 2P048K01 [A][A][B]**

**1.1 Sensing Supply**

[A] 110V 50Hz

**1.2 Time Delay**

[A] Approx 2 seconds

**1.3 Magnetic Blowouts**

[B] Not required

**1.4 Non-Standard Features**

Hardware specifications not described in Technical Bulletin.

None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification [162-048-800](#) and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

### 3.0 CONNECTION DIAGRAM

