



2V67-SK19 Test Manual

Multi Stage Voltage Relay

relay monitoring systems Pty Ltd

Advanced Protection Devices



User Guide



Test Manual



Relay Software



µMATRIXwin



2V67-SK19 Test Manual

Links to Other Documents

User Guide: http://www.rmspl.com.au/userguide/2v67-s_user_guide.pdf

Software Downloads: <http://www.rmspl.com.au/digital/umatrix.htm>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Factory Loaded UMX	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	03/05/2010	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DHW	DG	



1.0 HARDWARE SPECIFICATIONS – 2V067SK19 [A][A][A][B][A]

1.1 Auxiliary Supply

Auxiliary Supply Voltage [A] 20 - 70 VDC

1.2 Digital Input Operating Voltage – Group 1

Status Inputs Group 1 [A] 24 – 80V AC-DC

1.3 Digital Input Operating Voltage – Group 2

Status Inputs Group 2 [A] 24 - 80 V AC-DC

1.4 Voltage Inputs

[B] 1 Phase

1.5 Rear Communications Port

[A] Not fitted

1.6 Non-Standard Features

Hardware specifications not described in Data Sheet. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 165-067S-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE