



# 2V165-SK6 Test Manual

## Transformer Parallel Control Relay

relay monitoring systems pty ltd

### Advanced Protection Devices



User Guide



Test Manual



Relay Software



MATRIXwin



# 2V165-SK6 Test Manual

## Links to Other Documents

---

User Guide: [http://www.rmspl.com.au/userguide/2v165-s\\_user\\_guide.pdf](http://www.rmspl.com.au/userguide/2v165-s_user_guide.pdf)

Software Downloads: <http://www.rmspl.com.au/digital/umatrix.htm>

## Test Certification

---

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2000.

Order Number	Factory Loaded UMX	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

## Version Control

---

Issue	Date	Summary of changes
A	11/08/2009	Initial issue.

Due to RMS continuous product improvement policy, this information is subject to change without notice.  
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DHW	DG	



**1.0 HARDWARE SPECIFICATIONS – 2V165SK06 [A][D][D][D][B][B]**

- 1.1 Auxiliary Supply**  
 Auxiliary Supply Voltage [A] 20 - 70 VDC
- 1.2 Digital Input Operating Voltage – Group 1**  
 Status Inputs Group 1 [D] 18 – 275VAC 300VDC
- 1.3 Digital Input Operating Voltage – Group 2**  
 Status Inputs Group 2 [D] 18 - 275VAC 300VDC
- 1.4 Digital Input Operating Voltage – Group 3**  
 Status Inputs Group 3 [D] 18 - 275VAC 300VDC
- 1.5 Analogue Outputs**  
 [B] 4 – 20mA Output
- 1.6 Rear Communications Port**  
 [B] Modbus Protocol
- 1.7 Non-Standard Features**  
 Hardware specifications not described in Data Sheet. None

**2.0 VERIFICATION**

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2000.

Testing has been carried out against the declared performance specification 165-165S-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE