


3A203K1 Test Manual

Pilot Wire Intertrip Relay

relay monitoring systems pty ltd

Advanced Protection Devices



User Guide



Test Manual



3A203K1 Test Manual

Links to Other Documents

Technical Bulletin: <http://www.rmspl.com.au/handbook/3a20.pdf>

Test Certification

This is to certify that the equipment detailed below has been manufactured, inspected & tested in accordance with a Quality System which complies with the requirements of AS/NZS ISO9001-2008.

Order Number	Serial Number

Only valid when the "Passed" box has been signed off by Production Personnel.

Version Control

Issue	Date	Summary of changes
A	06/07/2011	Released.

Due to RMS continuous product improvement policy, this information is subject to change without notice.
This document is uncontrolled and subject to copyright.

Author	Checked & Registered	.pdf file created	Released
DG	DW	DW	



1.0 HARDWARE SPECIFICATIONS – 3A203K1 [C][B][B][A][A]-4M0B

(202) 2 X Receive Relays

- 1.1 Nominal Operate Voltage** [C] 48VDC
- 1.2 Contact Duty** [B] Standard duty
- 1.3 HV Insulation Withstand** [B] 5kV RMS
- 1.4 Case Style** [A] M Series
- 1.5 Flag Operation** [A] Hand reset flag
- 1.6 Contact Configuration** 4M0B 4 Make, 0 Break
- 1.7 Non-Standard Features**
 Hardware specifications not described in Technical Bulletin. None

2.0 VERIFICATION

This is to certify that the equipment has been manufactured, inspected and tested in accordance with a Quality System, which complies with the requirements of ISO9001: 2008.

Testing has been carried out against the declared performance specification 172-202-800 and in accordance with the relevant International (IEC) Standards.

PASSED BY	DATE

3.0 CONNECTION DIAGRAM

